



PEÑARANDA WATER DISTRICT

Gomez St. Poblacion II, Peñaranda, Nueva Ecija

Telefax No. (044) 940-4049/940-0971

Email Add. pwd1987@yahoo.com.ph

Website: www.pwd.gov.ph

PeñWD-PF #005-18

Date: May 21, 2024

Quotation No.: 2024-004

REQUEST FOR QUOTATION

Please quote your lowest price for the **Supply, Delivery, Installation, Testing and Commissioning of One (1) Unit Automatic Transfer Switch (ATS), 175 Amperes, 220 Volts, 60 Hertz, 3 Phase, with NEMA Enclosure**, subject to the conditions also listed below, stating the shortest time of delivery and submit your duly signed quotation on a sealed envelope not later than **5:00 p.m. of 28 May 2024** to the following address:

Bids and Awards Committee Secretariat
Peñaranda Water District
Gomez St., Poblacion 2
Peñaranda, Nueva Ecija
Telefax: (044) 940-4049
E-mail Address: pwd1987@yahoo.com.ph

(signed)
AVELINO G. ABELLO
BAC Chairperson

NOTE:

1. As a government agency, Peñaranda Water District (PeñWD) shall deal only with legitimate suppliers/contractors that issues BIR-registered official receipts and suppliers must passed the eligibility requirements for accreditation of **PeñWD**. Accreditation checklist may be downloaded at PeñWD website.
2. All entries shall be typewritten.
3. Quoted prices shall be inclusive of applicable taxes and shall be firm and valid for a period of at least thirty (30) days from the date of receipt of quotation & shall be binding upon the supplier within the period.
4. Delivery period shall be within fifteen (15) calendar days from receipt of Purchase Order.
5. Certificate of Site Inspection shall be submitted with the quotation.
6. Warranty shall be for a period of one (1) year from the date of acceptance.
7. PeñWD reserves the right to post-qualify any supplier and/or to reject any or all submitted quotations.
8. The P.O. shall be awarded to the lowest calculated responsive bid; delivered items are subject to inspection, with payment processing to commence only after acceptance by the end-users.
9. Valid PhilGEPS Registration Certificate shall be submitted with the quotation.
10. For Distributor- Valid Certificate of Distributorship of products being offered and/or Bureau of Product Standard (BPS) Certification shall be submitted with the quotation.
11. For Local Manufacturer- ISO Certification and Bureau of Product Standard (BPS) Certification shall be submitted with the quotation.
12. Terms of payment is sixty (60) calendar days after the date of inspection and acceptance.
13. Approved Budget for the Contract **₱ 150,000.00 (VAT inclusive)**
14. **Pre-bid Conference** shall be held on **May 24, 2024, 10:00 a.m.** at Peñaranda Water District Administration office.
15. **Request for Quotation and Quotation Form** may be purchased and/or downloaded by interested Bidders at PhilGEPS or PeñWD website on **May 22-28,2024**, provided payment of nonrefundable fee of Five Hundred Pesos (P500.00) was made to the PeñWD cashier or by bank transfer. Bank details for the payment will be provided upon request.

SUPPLY, DELIVERY, INSTALLATION, TESTING AND COMMISSIONING OF ONE
(1) UNIT AUTOMATIC TRANSFER SWITCH (ATS), 175 AMPERES, 220 VOLTS, 60
HERTZ, 3 PHASE, WITH NEMA ENCLOSURE

QUOTATION FORM

ITEM NO.	ITEM & DESCRIPTION (TECHNICAL SPECIFICATIONS)	QUANTITY	UNIT PRICE	TOTAL PRICE
1.	<p>Automatic Transfer Switch, ATS, Circuit breaker type, rated current; 175 amperes, voltage input 220 VAC, 60 Hertz, 3 phase, Breaking capacity in 36 kA, Class IP 54 with LCD display / LED indicator controller for manual and auto operation, integrated in Genset controller for dry contact signal input. Installed in a control box, powder coated paintings with power wiring, light indication for manual / auto operations and status for normal/emergency power supply. Control wirings from ATS controller for Signal to start Genset engine must be in applicable standard control wire size installed in a rigid steel conduit.</p> <p>Features and Operations:</p> <ul style="list-style-type: none">• TDEN – Time Delay Emergency to Normal: Adjustable range: 0-999 sec. TDEN delays the transfer from stand-by power source back to normal power source and to permit stabilization of before the transfer is made. Timing begins when the normal power source becomes available.• TDNE – Time Delay Normal to Emergency: Adjustable range: 0-999 secs. TDNE provides a time delay when transferring the normal power source to stand-by power source. It ensures the stand-by power source become available.• TDEC- Time Delay Engine Cool-Down: Adjustable range: 0-999 secs. TDEC permits the generator to continue to run unloaded after the transfer to the normal power source has occurred. Timing begins when the transfer to normal has been completed.• Test Mode: Simulate a loss of power source.• Auto Mode: Automatic Transfer form source to source as dictated by the features supplied and the program values.• SHT Power Delivery TRIP Device• Detection and Protection of Power abnormality under/over voltage, single phasing, unbalance power, voltage fluctuations, etc.	1 unit		

2.	Power Wiring <ul style="list-style-type: none">With Power Wire during Installation	1 lot		
3.	Testing, Commissioning, Including Warranty	1 lot		
TOTAL AMOUNT				
TOTAL AMOUNT IN WORDS:				

Name of Bidder : _____

Delivery Period : _____

Warranty : _____

Price Validity : _____

After having carefully read and accepted your conditions above, I/We quote you on the item at prices noted above.

Print Name / Signature

Tel. No. _____

Fax No. _____

E-Mail Address: _____

Date _____

TIN No. _____