



PEÑARANDA WATER DISTRICT

Gomez St. Poblacion II, Peñaranda, Nueva Ecija

Telefax No. (044) 940-4049/940-0971

Email Add. PeñWD1987@yahoo.com.ph

Website: www.PeñWD.gov.ph

PeñWD-PF #005-18

Date: May 23, 2024

Quotation No.: 2024-05

REQUEST FOR QUOTATION

Please quote your lowest price on the **SUPPLY, DELIVERY, TESTING AND COMMISSIONING OF ONE (1) UNIT 50KVA STAND-BY POWER DIESEL GENERATING SET, SILENT TYPE, 3 phase, 0.8 power factor, 230 volts, 60 hertz, 1800 rpm, 4-cylinder vertical in-line, coupled to a brushless alternator, housed in imported soundproof canopy with complete standard accessories.** subject to the conditions also listed below, stating the shortest time of delivery and submit your duly signed quotation in an envelope not later than **5:00 p.m. of 30 May 2024** to the following address:

Bids and Awards Committee Secretariat
Peñaranda Water District
Gomez St., Poblacion 2
Peñaranda, Nueva Ecija
Telefax: (044) 940-4049
E-mail Address: pwd1987@yahoo.com.ph

(signed)
AVELINO G. ABELLO
BAC Chairperson

NOTE:

1. As a government agency, Peñaranda Water District (PeñWD) shall deal only with legitimate suppliers/contractors that issues BIR-registered official receipts and suppliers must passed the eligibility requirements for accreditation of **PeñWD**. Accreditation checklist may be downloaded at PeñWD website.
2. All entries shall be typewritten.
3. Quoted prices shall be inclusive of applicable taxes and shall be firm and valid for a period of at least thirty (30) days from the date of receipt of quotation & shall be binding upon the supplier within the period.
4. Delivery, Positioning, Testing and Commissioning period shall be within fifteen (15) calendar days upon signing of Purchase Order.
5. Certificate of Site Inspection shall be submitted with the quotation.
6. The equipment and other accessories shall be guaranteed for a period of at least one (1) year or 1,500 hours operation whichever comes first of trouble-free operation.
7. Spare parts shall be available in the Philippine market.
8. Supplier must have a load testing facility which will provide the owner a Certificate of Load Testing Results for the unit to be supplied.
9. PeñWD reserves the right to post-qualify any supplier and/or to reject any or all submitted quotations.
10. The P.O. shall be awarded to the lowest calculated responsive bid; delivered items are subject to inspection, with payment processing to commence only after acceptance by the end-users.
11. Valid PhilGEPS Registration Certificate shall be submitted with the quotation.
12. For Distributor- Valid Certificate of Distributorship of products being offered and/or Bureau of Product Standard (BPS) Certification shall be submitted with the quotation and for imported products-valid ISO Certification.
13. For Manufacturer- ISO Certification and Bureau of Product Standard (BPS) Certification shall be submitted with the quotation.
14. Terms of payment is 30 calendar days after the date of inspection and acceptance.
15. Approved Budget for the Contract is **₱ 800,000.00 (VAT inclusive)**
16. **Pre-bid Conference** shall be held on **May 28, 2024, 10:00 a.m.** at Peñaranda Water District Administration office.
17. **Request for Quotation and Quotation Form** may be purchased and/or downloaded by interested Bidders at PhilGEPS or PeñWD website on **May 24-30, 2024**, provided payment of nonrefundable fee of Five Hundred Pesos (P500.00) was made to the PeñWD cashier.

QUOTATION FORM

| ITEM NO. | ITEM & DESCRIPTION (TECHNICAL SPECIFICATIONS) | QUANTITY | UNIT PRICE | TOTAL PRICE |
|------------------------|--|----------|------------|-------------|
| 1. | <p>SUPPLY, DELIVERY, TESTING AND COMMISSIONING OF ONE (1) UNIT 50KVA STAND-BY POWER DIESEL GENERATING SET, SILENT TYPE,3 phase, 0.8 power factor, 230 volts, 60 hertz, 1800 rpm, 4-cylinder vertical in-line, coupled to a brushless alternator, housed in imported soundproof canopy with complete standard accessories.</p> <p>Dimension (LWH)- 2300 x 1000 x 1540 mm Weight - 1150 kgs</p> <p>Genset Standard Accessories:</p> <ul style="list-style-type: none">• Suited Circuit breaker completely wired and tested.• Muffler, flexible pipe, flanges• Battery, Battery cable, battery isolator switch• Battery charger• Deepsea Digital Controller (Suited for manual and automatic operation)• Base mounted Fuel Tank (minimum of 80 lit. capacity)• Imported Enclosure with Emergency Stop Button <p>***Nothing Follows***</p> | 1 set | | |
| TOTAL AMOUNT | | | | |
| TOTAL AMOUNT IN WORDS: | | | | |

Name of Bidder :

Delivery Period :

Warranty :

Price Validity :

After having carefully read and accepted your conditions above, I/We quote you on the item at prices noted above.

Print Name / Signature

Tel. No.

Fax No.

E-Mail Address:

Date

TIN No.